

ENVIRONMENTAL LABWORKS, INC.

May 12, 2025

New Paltz CSD
196 Main Street
New Paltz, NY 12561

Dear James,

The following are results of the analyses performed on water samples from **Lenape Elementary School - Eugene L. Brown Drive, New Paltz, NY** received at the laboratory on 04/23/25.

Date/Time Collected: 04/23/25 7:18-7:37am First Draw
Collected By: UC BOCES
Project ID: 04232514
Secondary ID: LE251477-90

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Kitchen Sink 04232514-1	EPA 200.8 Lead	0.0025 mg/L	0.005 mg/L	04/28/25
Cafeteria Fountain 04232514-2	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
Cafeteria Bottle Fill 04232514-3	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
Gym Hall Right Fountain 04232514-4	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
Gym Hall Right Bottle Fill 04232514-5	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
Gym Hall Left Fountain 04232514-6	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
Gym Hall Left Bottle Fill 04232514-7	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
Main Lobby Fountain 04232514-8	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
Main Lobby Bottle Fill 04232514-9	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
Nurse Sink 04232514-10	EPA 200.8 Lead	0.0012 mg/L	0.005 mg/L	04/28/25


ENVIRONMENTAL LABWORKS, INC.

Lenape Elementary School - 04232514

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
2 nd Floor Hall Left Fountain 04232514-11	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
2 nd Floor Left Bottle Fill 04232514-12	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
2 nd Floor Hall Right Fountain 04232514-13	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25
2 nd Floor Hall Right Bottle Fill 04232514-14	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/28/25

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director