

ENVIRONMENTAL LABWORKS, INC.

May 12, 2025

New Paltz CSD
196 Main Street
New Paltz, NY 12561

Dear James,

The following are results of the analyses performed on water samples from **New Paltz High School - 130 S. Putt Corners Road, New Paltz, NY** received at the laboratory on 04/23/25.

Date/Time Collected: 04/23/25 6:24-7:07am First Draw
Collected By: UC BOCES
Project ID: 04232512
Secondary ID: NP251431-60

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Kitchen Prep Sink 1 04232512-1	EPA 200.8 Lead	0.0019 mg/L		0.005 mg/L	04/30/25
Kitchen Food Prep Sink 2 04232512-2	EPA 200.8 Lead	0.0027 mg/L		0.005 mg/L	04/30/25
Cafeteria Fountain 04232512-3	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Cafeteria Bottle Fill 04232512-4	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Gym Lobby Boys Fountain 04232512-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Gym Lobby Boys Bottle Fill 04232512-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Gym Lobby Girls Fountain 04232512-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Gym Lobby Girls Bottle Fill 04232512-8	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
2 nd Fl Hall by 216 Fountain 04232512-9	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25

ENVIRONMENTAL LABWORKS, INC.

New Paltz High School - 04232512

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
2 nd Fl Hall by 216 Bottle Fill 04232512-10	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Home Ec Sink 1 04232512-11	EPA 200.8 Lead	0.0012 mg/L		0.005 mg/L	04/30/25
Home Ec Sink 2 04232512-12	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Home Ec Sink 3 04232512-13	EPA 200.8 Lead	0.0012 mg/L		0.005 mg/L	04/30/25
Home Ec Sink 4 04232512-14	EPA 200.8 Lead	0.0018 mg/L		0.005 mg/L	04/30/25
2 nd Fl by Rm 243 Fountain 04232512-15	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
2 nd Fl by Rm 243 Bottle Fill 04232512-16	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Wellness Center Hall Fountain 04232512-17	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Wellness Hall Bottle Fill 04232512-18	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
New Wing Hall Fountain 04232512-19	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
New Wing Hall Bottle Fill 04232512-20	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Rm 150 Hose 04232512-21	EPA 200.8 Lead	0.355 mg/L	X	0.005 mg/L	04/30/25
Hall by 165 Fountain 04232512-22	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Hall by 165 Bottle Fill 04232512-23	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Rt Fountain by Rm 184 04232512-24	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25

ENVIRONMENTAL LABWORKS, INC.

New Paltz High School - 04232512


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Hall by 184 Right Bottle Fill 04232512-25	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Nurse Sink 04232512-26	EPA 200.8 Lead	0.0032 mg/L		0.005 mg/L	04/30/25
Girls Locker Rm Bottle Fill 04232512-27	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/01/25
By Girls Locker Rm Fountain 04232512-28	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Hall by 184 Left Bottle Fill 04232512-29	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Hall by 184 Left Fountain 04232512-30	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director