

ENVIRONMENTAL LABWORKS, INC.

May 12, 2025

New Paltz CSD
196 Main Street
New Paltz, NY 12561

Dear James,

The following are results of the analyses performed on water samples from **New Paltz Middle School - 196 Main Street, New Paltz, NY** received at the laboratory on 04/23/25.

Date/Time Collected: 04/23/25 5:28-6:13am First Draw
Collected By: UC BOCES
Project ID: 04232511
Secondary ID: NP251402-30

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Kitchen Island Sink 04232511-1	EPA 200.8 Lead	0.0027 mg/L		0.005 mg/L	04/30/25
Kitchen Main Sink 04232511-2	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Kitchen Prep Area Single Sink 04232511-3	EPA 200.8 Lead	0.0030 mg/L		0.005 mg/L	04/30/25
Kitchen Prep Double Sink 04232511-4	EPA 200.8 Lead	0.0012 mg/L		0.005 mg/L	04/30/25
Cafeteria Right Fountain 04232511-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Cafeteria Left Fountain 04232511-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Cafeteria Bottle Fill 04232511-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Courtyard Entrance Right Fountain 04232511-8	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Courtyard Entrance Bottle Fill 04232511-9	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Home Ec Sink 1 04232511-10	EPA 200.8 Lead	0.0018 mg/L		0.005 mg/L	04/30/25

ENVIRONMENTAL LABWORKS, INC.

New Paltz Middle School - 04232511

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Home Ec Sink 2 04232511-11	EPA 200.8 Lead	0.0069 mg/L	X	0.005 mg/L	04/30/25
Home Ec Sink 3 04232511-12	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	04/30/25
Home Ec Sink 4 04232511-13	EPA 200.8 Lead	0.0016 mg/L		0.005 mg/L	04/30/25
Home Ec Sink 5 04232511-14	EPA 200.8 Lead	0.0010 mg/L		0.005 mg/L	04/30/25
Home Ec Sink 6 04232511-15	EPA 200.8 Lead	0.0100 mg/L	X	0.005 mg/L	04/30/25
Nurse Main Sink 04232511-16	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Locker Rm Hall Fountain Right 04232511-17	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Locker Rm Hall Bottle Fill 04232511-18	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Hall by Rm 25 Fountain 04232511-19	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Hall by Rm 23 Bottle Fill 04232511-20	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Library Hall Fountain 04232511-21	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Library Hall Bottle Fill 04232511-22	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
7 th Grade Hall Fountain 04232511-23	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
7 th Grade Hall Bottle Fill 04232511-24	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
8 th Grade Hall Fountain 04232511-25	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25

ENVIRONMENTAL LABWORKS, INC.

New Paltz Middle School - 04232511


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
8 th Grade Hall Bottle Fill 04232511-26	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Lobby Fountain 04232511-27	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Lobby Bottle Fill 04232511-28	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/30/25
Kitchenette Sink 04232511-29	EPA 200.8 Lead	0.0054 mg/L	X	0.005 mg/L	04/30/25

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director